

Attention:

Rapid Shutdown

The City of Lincoln will now require photovoltaic systems to comply with sections 690.12 and 690.56 (C)

2016 CEC art.690.12-The City of Lincoln requires a formal letter stating that the photovoltaic system compliance for rapid shutdown has been completed and the letter needs to state the method used. (This letter is to be submitted at the time of the final inspection).

2016 CEC 690.56 (C) the label requirements for this section shall state the following:

“PHOTOVOLTAIC SYSTEM EQUIPPED WITH RAPID SHUTDOWN”

This label shall be reflective, all letters capitalized, having a minimum letter height 3/8” in white on red background.